

1712 S Faraday Avenue – Housing Code Violations:

304.10: Stairways, decks, porches, and balconies - Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained, structurally safe and sound, and in good repair, with proper anchorage and capable of supporting the imposed loads.

- Front porch roof, ceiling, pillars, fascia all in disrepair.

304.2: Protective Treatment - All exterior surfaces, including but not limited to, doors, door and window frames, cornices, porches, trim, balconies, decks and fences shall be maintained in good condition. Exterior wood surfaces, other than decay-resistant woods, shall be protected from the elements and decay by painting or other protective covering or treatment. Peeling, flaking, and chipped paint shall be eliminated and surfaces repainted. All siding and masonry joints as well as those between the building envelop and the perimeter of windows, doors, and skylights shall be maintained weather resistant and water tight. All metal surfaces subject to rust or corrosion shall be coated to inhibit such rust and corrosion and all surfaces with rust or corrosion shall be stabilized and coated to inhibit future rust and corrosion. Oxidation stains shall be removed from exterior surfaces.

- Rear upper window and window trim in disrepair.

304.5: Foundation walls - All foundation walls shall be maintained plumb and free from open cracks and breaks and shall be kept in such condition so as to prevent the entry of rodents and other pests.

- Foundation walls in disrepair.

304.6: Exterior walls - All exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent deterioration.

- Exterior walls chipping in disrepair.

304.7: Roofs and drainage - The roof and flashing shall be sound tight and not have any defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspout shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.

- The roof, gutters and soffits are in disrepair

304.9: Overhang extensions - All overhang extensions including but not limited to canopies, marquees, signs, metal awnings, fire escapes, standpipes and exhaust ducts shall be maintained in good repair and properly anchored so as to be kept in sound condition. When required, all exposed surfaces of metal or wood shall be protected from the elements and against decay or rust by periodic application of weather coating materials such as paint or similar surface treatment.

- Rear awning in disrepair.



06-20-2025 10:43 AM



06-20-2025 10:39 AM











